

# Flexit Nordic S3

## • WITH LOCAL DEMAND CONTROL

CTRL 0,65

### LOCAL DEMAND CONTROL

Sensor control for different zones

**Accessories:** App + CO<sub>2</sub>-sensor/motion sensor + damper

**Result:** Increased air flow rate in zones that need it

Energiklasse: **A**

a)	Name or trade mark:	Flexit
b)	Model identifier:	Nordic S3 RER Art.no. 800120 Nordic S3 R R Art.no. 800122
c)	Specific energy consumption (SEC): $SEC = t_a \cdot p_{ef} \cdot q_{net} \cdot MISC \cdot CTRL^x \cdot SPI - t_h \cdot \Delta T_h \cdot \eta_h^{-1} \cdot c_{air} \cdot (q_{ref} - q_{net} \cdot CTRL \cdot MISC \cdot (1 - \eta_t)) + Q_{defr}$	Cold -83,7 kWh/m <sup>2</sup> and years Average -40,6 kWh/m <sup>2</sup> and years Warm -15,9 kWh/m <sup>2</sup> and years
d)	Typology:	Bidirectional ventilation unit for residential
e)	Drive:	Variable speed drive (X=2,0)
f)	Heat recovery system:	Regenerativ heat exchanger
g)	Thermal efficiency (EN 13141-7):	81%
h)	Maximum flow rate:	345 m <sup>3</sup> /h
i)	Electric power input of the drive:	178 W
j)	Sound power level (Lw(A)):	39 dB(A)
k)	Reference flow rate:	0,0671 m <sup>3</sup> /s (242 m <sup>3</sup> /h)
l)	Reference pressure difference:	50 Pa
m)	Specific Power Input (SPI):	0,34 W/(m <sup>3</sup> /h)
n)	Control factor and control typology:	0,65
o)	Leakage:	External leakage: 2 % Internal leakage: 5 %
p)	Mixing rate:	n.a
q)	Filter warning:	Filter warning indicated on the control panel. *
r)	For unidirectional ventilation systems:	n.a
s)	Pre-/dis-assembly instructions:	www.flexit.no
t)	For non-ducted units: Pressure variations	n.a
u)	For non-ducted units: Air tightness	n.a
v)	The annual electricity consumption: $AEC = t_a \cdot q_{net} \cdot MISC \cdot CTRL^x \cdot SPI + Q_{defr}$	180 kWh/100m <sup>2</sup> and years
w)	The annual heating saved: $AHS = t_h \cdot \Delta T_h \cdot \eta_h^{-1} \cdot c_{air} \cdot (q_{ref} - q_{net} \cdot CTRL \cdot MISC \cdot (1 - \eta_t))$	Cold 8817 kWh/year Average 4507 kWh/year Warm 2038 kWh/year

This document describes:

**COMMISSION REGULATION (EU) No 1253/2014 of 7 July 2014**  
implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for ventilation units.

**COMMISSION DELEGATED REGULATION (EU) No 1254/2014 of 11 July 2014**  
supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to energy labelling of residential ventilation units.

) Ref. 1253/2014 and 1254/2014

\*In order to achieve the optimal indoor climate it is crucial to change filter on a regular basis. This will also result in better economy and less noise compared with clogged.

# Flexit Nordic S3

## • CENTRAL DEMAND CONTROL

CTRL 0,85

### CENTRAL DEMAND CONTROL

Sensor control for part of/whole building

**Accessories:** App + CO<sub>2</sub>-sensor/motion sensor

**Result:** Increased air flow for whole building

Energiklasse: **A**

a)	Name or trade mark:	Flexit
b)	Model identifier:	Nordic S3 RER Art.no. 800120 Nordic S3 R R Art.no. 800122
c)	Specific energy consumption (SEC): $SEC = t_a \cdot p_{ef} \cdot q_{net} \cdot MISC \cdot CTRL^x \cdot SPI - t_h \cdot \Delta T_h \cdot \eta_h^{-1} \cdot c_{air} \cdot (q_{ref} - q_{net} \cdot CTRL \cdot MISC \cdot (1 - \eta_t)) + Q_{defr}$	Cold -78,1 kWh/m <sup>2</sup> and years Average -36,2 kWh/m <sup>2</sup> and years Warm -12,1 kWh/m <sup>2</sup> and years
d)	Typology:	Bidirectional ventilation unit for residential
e)	Drive:	Variable speed drive (X=2,0)
f)	Heat recovery system:	Regenerativ heat exchanger
g)	Thermal efficiency (EN 13141-7):	81%
h)	Maximum flow rate:	345 m <sup>3</sup> /h
i)	Electric power input of the drive:	178 W
j)	Sound power level (Lw(A)):	39 dB(A)
k)	Reference flow rate:	0,0671 m <sup>3</sup> /s (242 m <sup>3</sup> /h)
l)	Reference pressure difference:	50 Pa
m)	Specific Power Input (SPI):	0,34 W/(m <sup>3</sup> /h)
n)	Control factor and control typology:	0,85
o)	Leakage:	External leakage: 2 % Internal leakage: 5 %
p)	Mixing rate:	n.a
q)	Filter warning:	Filter warning indicated on the control panel. *
r)	For unidirectional ventilation systems:	n.a
s)	Pre-/dis-assembly instructions:	www.flexit.no
t)	For non-ducted units: Pressure variations	n.a
u)	For non-ducted units: Air tightness	n.a
v)	The annual electricity consumption: $AEC = t_a \cdot q_{net} \cdot MISC \cdot CTRL^x \cdot SPI + Q_{defr}$	308 kWh/100m <sup>2</sup> and years
w)	The annual heating saved: $AHS = t_h \cdot \Delta T_h \cdot \eta_h^{-1} \cdot c_{air} \cdot (q_{ref} - q_{net} \cdot CTRL \cdot MISC \cdot (1 - \eta_t))$	Cold 8580 kWh/year Average 4386 kWh/year Warm 1983 kWh/year

This document describes:

**COMMISSION REGULATION (EU) No 1253/2014 of 7 July 2014**  
implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for ventilation units.

**COMMISSION DELEGATED REGULATION (EU) No 1254/2014 of 11 July 2014**  
supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to energy labelling of residential ventilation units.

) Ref. 1253/2014 and 1254/2014

\*In order to achieve the optimal indoor climate it is crucial to change filter on a regular basis. This will also result in better economy and less noise compared with clogged.

# Flexit Nordic S3

• WITH TIMER

CTRL 0,95

## TIMER

Timer control

Accessories: App

Result: Increased air flow for whole building

Energiklasse: **B**

a)	Name or trade mark:	Flexit
b)	Model identifier:	Nordic S3 RER Art.no. 800120 Nordic S3 R R Art.no. 800122
c)	Specific energy consumption (SEC): $SEC = t_a \cdot p_{ef} \cdot q_{net} \cdot MISC \cdot CTRL^x \cdot SPI - t_h \cdot \Delta T_h \cdot \eta_h^{-1} \cdot c_{air} \cdot (q_{ref} - q_{net} \cdot CTRL \cdot MISC \cdot (1 - \eta_t)) + Q_{defr}$	Cold -74,8 kWh/m <sup>2</sup> and years Average -33,4 kWh/m <sup>2</sup> and years Warm -9,7 kWh/m <sup>2</sup> and years
d)	Typology:	Bidirectional ventilation unit for residential
e)	Drive:	Multi-speed drive (X=1,5)
f)	Heat recovery system:	Regenerativ heat exchanger
g)	Thermal efficiency (EN 13141-7):	81%
h)	Maximum flow rate:	345 m <sup>3</sup> /h
i)	Electric power input of the drive:	178 W
j)	Sound power level (Lw(A)):	39 dB(A)
k)	Reference flow rate:	0,0671 m <sup>3</sup> /s (242 m <sup>3</sup> /h)
l)	Reference pressure difference:	50 Pa
m)	Specific Power Input (SPI):	0,34 W/(m <sup>3</sup> /h)
n)	Control factor and control typology:	0,95
o)	Leakage:	External leakage: 2 % Internal leakage: 5 %
p)	Mixing rate:	n.a
q)	Filter warning:	Filter warning indicated on the control panel. *
r)	For unidirectional ventilation systems:	n.a
s)	Pre-/dis-assembly instructions:	www.flexit.no
t)	For non-ducted units: Pressure variations	n.a
u)	For non-ducted units: Air tightness	n.a
v)	The annual electricity consumption: $AEC = t_a \cdot q_{net} \cdot MISC \cdot CTRL^x \cdot SPI + Q_{defr}$	394 kWh/100m <sup>2</sup> and years
w)	The annual heating saved: $AHS = t_h \cdot \Delta T_h \cdot \eta_h^{-1} \cdot c_{air} \cdot (q_{ref} - q_{net} \cdot CTRL \cdot MISC \cdot (1 - \eta_t))$	Cold 8462 kWh/year Average 4325 kWh/year Warm 1956 kWh/year

This document describes:

COMMISSION REGULATION (EU) No 1253/2014 of 7 July 2014 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for ventilation units.

COMMISSION DELEGATED REGULATION (EU) No 1254/2014 of 11 July 2014 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to energy labelling of residential ventilation units.

) Ref. 1253/2014 and 1254/2014

\*In order to achieve the optimal indoor climate it is crucial to change filter on a regular basis. This will also result in better economy and less noise compared with clogged.

# Flexit Nordic S3

• WITH MANUAL CONTROL

CTRL 1,0

## MANUAL CONTROL

Forcing switch control

Accessories: CI 70/app/CI 78

Result: Increased air flow for whole building

Energiklasse: **B**

a)	Name or trade mark:	Flexit
b)	Model identifier:	Nordic S3 RER Art.no. 800120 Nordic S3 R R Art.no. 800122
c)	Specific energy consumption (SEC): $SEC = t_a \cdot p_{ef} \cdot q_{net} \cdot MISC \cdot CTRL^x \cdot SPI - t_h \cdot \Delta T_h \cdot \eta_h^{-1} \cdot c_{air} \cdot (q_{ref} - q_{net} \cdot CTRL \cdot MISC \cdot (1 - \eta_t)) + Q_{defr}$	Cold -73,4 kWh/m <sup>2</sup> and years Average -32,3 kWh/m <sup>2</sup> and years Warm -8,8 kWh/m <sup>2</sup> and years
d)	Typology:	Bidirectional ventilation unit for residential
e)	Drive:	Multi-speed drive (X=1,5)
f)	Heat recovery system:	Regenerativ heat exchanger
g)	Thermal efficiency (EN 13141-7):	81%
h)	Maximum flow rate:	345 m <sup>3</sup> /h
i)	Electric power input of the drive:	178 W
j)	Sound power level (Lw(A)):	39 dB(A)
k)	Reference flow rate:	0,0671 m <sup>3</sup> /s (242 m <sup>3</sup> /h)
l)	Reference pressure difference:	50 Pa
m)	Specific Power Input (SPI):	0,34 W/(m <sup>3</sup> /h)
n)	Control factor and control typology:	1,0
o)	Leakage:	External leakage: 2 % Internal leakage: 5 %
p)	Mixing rate:	n.a
q)	Filter warning:	Filter warning indicated on the control panel. *
r)	For unidirectional ventilation systems:	n.a
s)	Pre-/dis-assembly instructions:	www.flexit.no
t)	For non-ducted units: Pressure variations	n.a
u)	For non-ducted units: Air tightness	n.a
v)	The annual electricity consumption: $AEC = t_a \cdot q_{net} \cdot MISC \cdot CTRL^x \cdot SPI + Q_{defr}$	426 kWh/100m <sup>2</sup> and years
w)	The annual heating saved: $AHS = t_h \cdot \Delta T_h \cdot \eta_h^{-1} \cdot c_{air} \cdot (q_{ref} - q_{net} \cdot CTRL \cdot MISC \cdot (1 - \eta_t))$	Cold 8403 kWh/year Average 4295 kWh/year Warm 1942 kWh/year

This document describes:

COMMISSION REGULATION (EU) No 1253/2014 of 7 July 2014  
implementing Directive 2009/125/EC of the European Parliament and of  
the Council with regard to ecodesign requirements for ventilation units.

COMMISSION DELEGATED REGULATION (EU) No 1254/2014 of 11  
July 2014  
supplementing Directive 2010/30/EU of the European Parliament and of  
the Council with regard to energy labelling of residential ventilation units.

) Ref. 1253/2014 and 1254/2014

\*In order to achieve the optimal indoor climate it is crucial to change filter on a regular basis.  
This will also result in better economy and less noise compared with clogged.